Statement of Deficiencies	**(X1) Provider/Supplier/CLIA Identification Number**	**(X3) Date Survey Completed**
	55C0001059	05/12/2026
Name of Provider or Supplier	**Street Address, City, State**	
Fort Sutter Surgery Center, A Ca Limited Partnership	2801 K Street, Suite 525, Sacramento, CA	

For information on the provider's plan to correct this deficiency, please contact the provider or the state survey agency.

(X4) ID Prefix Tag	**Summary Statement of Deficiencies** (Each deficiency should be preceded by full regulatory or LSC identifying information)
K0291	Emergency Lighting CFR(s): NFPA 101 Emergency Lighting Emergency lighting of at least 1-1/2 hour duration is provided automatically in accordance with 7.9. 20.2.9.1, 21.2.9.1, 7.9 This STANDARD is not met as evidenced by: Based on record review and interview, the facility failed to maintain the emergency battery backup lighting. This was evidenced by the failure to provide annual test records. This affected all patients and could result in a failure of the battery backup lighting system during an emergency. NFPA 101 Life Safety Code, 2012 edition 21.2.9.1 Emergency lighting shall be provided in accordance with Section 7.9. 7.9 Emergency Lighting. 7.9.3 Periodic Testing of Emergency Lighting Equipment. 7.9.3.1 Required emergency lighting systems shall be tested in accordance with one of the three options offered by 7.9.3.1.1, 7.9.3.1.2, or 7.9.3.1.3. 7.9.3.1.1 Testing of required emergency lighting systems shall be permitted to be conducted as follows:

	(1) Functional testing shall be conducted monthly, with a minimum of 3 weeks and a maximum of 5 weeks between tests, for not less than 30 seconds, except as otherwise permitted by 7.9.3.1.1(2). (2)* The test interval shall be permitted to be extended beyond 30 days with the approval of the authority having jurisdiction. (3) Functional testing shall be conducted annually for a minimum of 11/ 2 hours if the emergency lighting system is battery powered. (4) The emergency lighting equipment shall be fully operational for the duration of the tests required by 7.9.3.1.1(1) and (3). (5) Written records of visual inspections and tests shall be kept by the owner for inspection by the authority having jurisdiction. Findings: During record review and interview with Staff on 5/12/26, the emergency lighting testing records were reviewed. At 11:58 a.m., the facility failed to provide the annual 90-minute testing records for the battery backup emergency lights in the facility. No records were available for review. Upon interview, the Nurse Manager stated that the lights were tested annually but they did not have the testing records.