Statement of Deficiencies	**(X1) Provider/Supplier/CLIA Identification Number**	**(X3) Date Survey Completed**
	55C0001059	05/12/2026
Name of Provider or Supplier	**Street Address, City, State**	
Fort Sutter Surgery Center, A Ca Limited Partnership	2801 K Street, Suite 525, Sacramento, CA	

For information on the provider's plan to correct this deficiency, please contact the provider or the state survey agency.

(X4) ID Prefix Tag	**Summary Statement of Deficiencies** (Each deficiency should be preceded by full regulatory or LSC identifying information)
K0711	Evacuation and Relocation Plan CFR(s): NFPA 101 Evacuation and Relocation Plan There is a written plan for the protection of all patients and for their evacuation in the event of an emergency. Employees are periodically instructed and kept informed with their duties under the plan, and a copy of the plan is readily available with telephone operator or with security. The plan addresses the basic response required of staff per 20/21.7.2.1.2 and provides for all of the fire safety plan components per 20/21.7.2.2. 20.7.1.1 through 20.7.1.3, 20.7.1.8 through 20.7.2.3.3 21.7.1.1 through 20.7.1.3, 21.7.1.8 through 20.7.2.3.3 This STANDARD is not met as evidenced by: Based on record review and interview, the facility failed to maintain their fire safety plan. This was evidenced by the failure to address how they would prepare the floors and building for an evacuation. This affected all patients and could result in staff being untrained and unaware of their roles and responsibilities in the event of an evacuation. NFPA 101: Life Safety Code, 2012 Edition 21.7.2.2 Fire Safety Plan. A written health care occupancy fire safety plan shall provide for all of the following: (1) Use of alarms

	(2) Transmission of alarms to fire department (3) Emergency phone call to fire department (4) Response to alarms (5) Isolation of fire (6) Evacuation of immediate area (7) Evacuation of smoke compartment (8) Preparation of floors and building for evacuation (9) Extinguishment of fire Findings: During record review, and interview with Staff on 5/12/26, the fire safety plan was reviewed. At 2:02 p.m., the facility's fire safety plan failed to include a process for clearing the corridors of wheeled equipment in the event of an evacuation. Upon interview, the Administrator acknowledged that they were unable to provide a written policy for clearing the corridors for an evacuation.