Statement of Deficiencies	**(X1) Provider/Supplier/CLIA Identification Number**	**(X3) Date Survey Completed**
	55C0001062	04/30/2018
Name of Provider or Supplier	**Street Address, City, State**	
Sacramento Eye Surgicenter	3150 J Street, Sacramento, CA	

For information on the provider's plan to correct this deficiency, please contact the provider or the state survey agency.

(X4) ID Prefix Tag	**Summary Statement of Deficiencies** (Each deficiency should be preceded by full regulatory or LSC identifying information)
K0346	Fire Alarm System - Out of Service CFR(s): NFPA 101 Fire Alarm - Out of Service Fire alarms that are out of service for 4 hours in a 24 hour period, the authority having jurisdiction shall be notified, and the building shall be evacuated or an approved fire watch shall be provided for all parties left unprotected by the shutdown until the fire alarm system has been returned to service. 9.6.1.6 This STANDARD is not met as evidenced by: Based on document review and interview, the facility failed to maintain the fire alarm system out of service policy. This was evidenced by the absence of notification to the authority having jurisdiction (AHJ) due to malfunction system. This affected all patients and could result in delayed emergency assistance in the event of a fire during fire alarm system disruption. Findings: During document review and interview with the Administrator on 4/30/18, the fire alarm system out of service policy was requested. 1. At 11:02 a.m., the policy did not include notification to the AHJ (California Department of Public Health) when the fire alarm system was of service for more than four hours in a 24-hour period. Upon interview, the Administrator confirmed the

	finding.