Statement of Deficiencies	**(X1) Provider/Supplier/CLIA Identification Number**	**(X3) Date Survey Completed**
	55C0001062	04/30/2018
Name of Provider or Supplier	**Street Address, City, State**	
Sacramento Eye Surgicenter	3150 J Street, Sacramento, CA	

For information on the provider's plan to correct this deficiency, please contact the provider or the state survey agency.

(X4) ID Prefix Tag	**Summary Statement of Deficiencies** (Each deficiency should be preceded by full regulatory or LSC identifying information)
K0354	Sprinkler System - Out of Service CFR(s): NFPA 101 Sprinkler System - Out of Service Where the sprinkler system is impaired, the extent and duration of the impairment has been determined, areas or buildings involved are inspected and risks are determined, recommendations are submitted to management or designated representative, and the fire department and other authorities having jurisdiction have been notified. Where the sprinkler system is out of service for more than 10 hours in a 24 hour period, the building or portion of the building affected are evacuated or an approved fire watch is provided until the sprinkler system has been returned to service. 9.7.5, 15.5.2 (NFPA 25) This STANDARD is not met as evidenced by: Based on document review and interview, the facility failed to maintain the automatic sprinkler system out of service policy. This was evidenced by the absence of notification to the authority having jurisdiction (AHJ) due to malfunction system. This affected all patients and could result in delayed emergency assistance in the event of a fire during automatic sprinkler system disruption. Findings: During document review and interview with the Administrator on 4/30/18, the automatic sprinkler system out of service policy was requested.

	1. At 11:02 a.m., the policy did not include notification to the AHJ (California Department of Public Health) when the automatic sprinkler system was of service for more than ten hours in a 24-hour period. Upon interview, the Administrator confirmed the finding.