Statement of Deficiencies	**(X1) Provider/Supplier/CLIA Identification Number**	**(X3) Date Survey Completed**
	55C0001062	04/30/2018
Name of Provider or Supplier	**Street Address, City, State**	
Sacramento Eye Surgicenter	3150 J Street, Sacramento, CA	

For information on the provider's plan to correct this deficiency, please contact the provider or the state survey agency.

(X4) ID Prefix Tag	**Summary Statement of Deficiencies** (Each deficiency should be preceded by full regulatory or LSC identifying information)
K0500	Building Services - Other CFR(s): NFPA 101 Building Services - Other List in the REMARKS section any LSC Section 20.5 and 21.5 Building Services requirements that are not addressed by the provided K-tags, but are deficient. This information, along with the applicable Life Safety Code or NFPA standard citation, should be included on Form CMS-2567. This STANDARD is not met as evidenced by: Based on observation and interview, the facility failed to maintain the electrical system. This was evidenced by two electrical panels that had circuit breaker switches that were not labeled correctly, one panel that was missing circuit breaker switch cover plates, and another that was covered with dust and lent. This affected all patients and could result in the ignition of an electrical fire. NFPA 101, Life Safety Code, 2012 edition 21.5.1 Utilities. 21.5.1.1 Utilities shall comply with the provisions of Section 9.1 9.1.2 Electrical Systems. Electrical wiring and equipment shall be in accordance with NFPA 70, National Electrical Code, unless such installations are approved existing installations, which shall be permitted to be continued in service.

NFPA 70 National Electrical Code, 2011 Edition

110.22 Identification of Disconnecting Means.

(A) General. Each disconnecting means shall be legibly marked to indicate its purpose unless located and arranged so the purpose is evident. The marking shall be of sufficient durability to withstand the environment involved.

408.4 Field Identification Required.

(A) Circuit Directory or Circuit Identification. Every circuit and circuit modification shall be legibly identified as to its clear, evident, and specific purpose or use. The identification shall include sufficient detail to allow each circuit to be distinguished from all others. Spare positions that contain unused overcurrent devices or switches shall be described accordingly. The identification shall be included in a circuit directory that is located on the face or inside of the panel door in the case of a panelboard, and located at each switch or circuit breaker in a switchboard. No circuit shall be described in a manner that depends on transient conditions of occupancy.

408.7 Unused Openings. Unused openings for circuit breakers and switches shall be closed using identified closures, or other approved means that provide protection substantially equivalent to the wall of the enclosure.

Findings:

During a tour of the facility with the Administrator on 4/30/18, the electrical system was observed.

1. At 11:28 a.m., the electrical panels located in the corridor area outside OR 1 were observed. Circuit breaker switches 16 and 35 in Panel S were in the on position, but were not labeled. Circuit breaker switches 39 and 40 in Panel E were missing filler plates. Panel F had lint and dust covering the lower portion of the circuit breaker switches.

2. At 12:02 p.m., the electrical panel in the UPS Room was observed. Circuit breaker switches 16, 19, 21, and 23 were in the on position, but were not labeled.

These findings were confirmed by the Administrator.