Statement of Deficiencies	**(X1) Provider/Supplier/CLIA Identification Number**	**(X3) Date Survey Completed**
	55C0001062	09/08/2026
Name of Provider or Supplier	**Street Address, City, State**	
Sacramento Eye Surgicenter	3150 J Street, Sacramento, CA	

For information on the provider's plan to correct this deficiency, please contact the provider or the state survey agency.

(X4) ID Prefix Tag	**Summary Statement of Deficiencies** (Each deficiency should be preceded by full regulatory or LSC identifying information)
K0211	Means of Egress - General CFR(s): NFPA 101 Means of Egress - General Aisles, passageways, corridors, exit discharges, exit locations, and accesses are in accordance with Chapter 7, and the means of egress is continuously maintained free of all obstructions to full instant use in case of emergency, unless modified by 20/21.2.2 through 20/21.2.11. 20.2.1, 21.2.1, 7.1.10.1 This STANDARD is not met as evidenced by: Based on observation and interview, the facility failed to maintain the corridor doors. This was evidenced by obstructed corridor doors. This can increase the passage of smoke through smoke compartments. This affected 16 of 16 patients and four of four smoke compartments. Findings: During a tour of the facility and interview with the staff on 9/8/26, the corridor doors were observed.

	1. At 11:50 a.m., the corridor door to the Visual Field-Testing Room was observed with a self-closing mechanism. The corridor door was observed obstructed from closure by a yellow wedge-style doorstop. The doorstop was observed at the base of the door. During a concurrent interview, Staff 1 confirmed the finding and stated that she was unaware of the use of the doorstop. 2. At 11:50 a.m., the corridor door to the Storage Room by the Employee Break Room was observed with a self-closing mechanism. The corridor door was observed obstructed from closure by a wedge-style doorstop. The doorstop was observed at the base of the door. During a concurrent interview, Staff 1 confirmed the finding and stated that she was unaware of the use of the doorstop.