Statement of Deficiencies	**(X1) Provider/Supplier/CLIA Identification Number**	**(X3) Date Survey Completed**
	55C0001076	07/10/2019
Name of Provider or Supplier	**Street Address, City, State**	
Plastic Surg Assoc Of Orange County	1310 Stewart Drive, Suite 610, Orange, CA	

For information on the provider's plan to correct this deficiency, please contact the provider or the state survey agency.

(X4) ID Prefix Tag	**Summary Statement of Deficiencies** (Each deficiency should be preceded by full regulatory or LSC identifying information)
K0712	Fire Drills CFR(s): NFPA 101 Fire Drills Fire drills include the transmission of a fire alarm signal and simulation of emergency fire conditions. Fire drills are held at expected and unexpected times under varying conditions, at least quarterly on each shift The staff is familiar with procedures and is aware that drills are part of established routine. Where drills are conducted between 9:00 PM and 6:00 AM, a coded announcement may be used instead of audible alarms. 21.7.1.4 through 21.7.1.7 This STANDARD is not met as evidenced by: Based on record review and interview, the facility failed to provide complete documentation of fire drills. This was evidenced by failing to conduct three of four fire drills for the last 12 months. This affected the facility. This finding could result in failure of staff to protect their patients in the event of a fire. NFPA 101. Life Safety Code 2012 Edition 21.7.1.4* Fire drills in ambulatory health care facilities shall include the transmission of a fire alarm signal and simulation of emergency fire conditions. 21.7.2.3.1 All personnel shall be instructed in the use of and response to fire alarms.

	Findings: During record review with the Medical Assistance on 7/10/19, the fire drills records were reviewed. 1. At 9:30 a.m., the facility failed to provide documents to show three of four fire drills were conducted within the last 12 months. During an interview with Medical Assistance, she stated the Building Maintenance is in charge of conducting the fire drills and believed the requirement was one fire drill per year. 2. At 9:32 a.m., the facility's fire drill record, dated 6/19, failed to indicate real life fire condition scenarios.