

<b>Statement of Deficiencies</b>	<b>(X1) Provider/Supplier/CLIA Identification Number</b>  010001	<b>(X3) Date Survey Completed</b>  10/05/2017
<b>Name of Provider or Supplier</b>  Southeast Health Medical Center	<b>Street Address, City, State</b>  1108 Ross Clark Circle, Dothan, AL	
For information on the provider's plan to correct this deficiency, please contact the provider or the state survey agency.		

<b>(X4) ID Prefix Tag</b>	<b>Summary Statement of Deficiencies</b>  (Each deficiency should be preceded by full regulatory or LSC identifying information)
<b>K0355</b>	<p>Portable Fire Extinguishers CFR(s): NFPA 101</p> <p>Portable Fire Extinguishers Portable fire extinguishers are selected, installed, inspected, and maintained in accordance with NFPA 10, Standard for Portable Fire Extinguishers. 18.3.5.12, 19.3.5.12, NFPA 10</p> <p>This STANDARD is not met as evidenced by:                      . Based on observation and interview, the building failed to maintain the fire extinguishers per the requirements of: 2012 NFPA 101, 19.3.5.12 2012 NFPA 101, 9.7.4.1 2010 NFPA 10, 6.1.3.8.1 2010 NFPA 10, 6.1.3.8.3 2010 NFPA 10, 7.2.2 2010 NFPA 10, 5.5.5.3 Findings include: 1. On 10/03/2017, during a tour of the building from 8:00 am to 4:15 pm, the following was observed on the First Floor: a. In the Mechanical Room for Case Management a fire extinguisher was observed on the floor and it had just been inspected the day before. b. In the Insurance Suite by the water fountain a fire extinguisher was observed mounted over 5'-0" above finished floor and it had just been inspected the day before. DEVIN c. A portable fire extinguisher in the Special Procedure's Speech Therapy Office was observed obstructed by three large filing cabinets. 36148 2. On 10/04/2017, during a tour of the building from 8:00 am to 5:00 pm, the K fire extinguisher at the Service Line Grill area was observed without a placard placed near the extinguisher. A member of the maintenance staff was present when this deficiency was identified. .</p>