

<b>Statement of Deficiencies</b>	<b>(X1) Provider/Supplier/CLIA Identification Number</b>  010001	<b>(X3) Date Survey Completed</b>  10/05/2017
<b>Name of Provider or Supplier</b>  Southeast Health Medical Center	<b>Street Address, City, State</b>  1108 Ross Clark Circle, Dothan, AL	
For information on the provider's plan to correct this deficiency, please contact the provider or the state survey agency.		

<b>(X4) ID Prefix Tag</b>	<b>Summary Statement of Deficiencies</b>  (Each deficiency should be preceded by full regulatory or LSC identifying information)
<b>K0923</b>	<p>Gas Equipment - Cylinder and Container Storage CFR(s): NFPA 101</p> <p>Gas Equipment - Cylinder and Container Storage Greater than or equal to 3,000 cubic feet Storage locations are designed, constructed, and ventilated in accordance with 5.1.3.3.2 and 5.1.3.3.3. &gt;300 but &lt;3,000 cubic feet Storage locations are outdoors in an enclosure or within an enclosed interior space of non- or limited- combustible construction, with door (or gates outdoors) that can be secured. Oxidizing gases are not stored with flammables, and are separated from combustibles by 20 feet (5 feet if sprinklered) or enclosed in a cabinet of noncombustible construction having a minimum 1/2 hr. fire protection rating. Less than or equal to 300 cubic feet In a single smoke compartment, individual cylinders available for immediate use in patient care areas with an aggregate volume of less than or equal to 300 cubic feet are not required to be stored in an enclosure. Cylinders must be handled with precautions as specified in 11.6.2. A precautionary sign readable from 5 feet is on each door or gate of a cylinder storage room, where the sign includes the wording as a minimum "CAUTION: OXIDIZING GAS(ES) STORED WITHIN NO SMOKING." Storage is planned so cylinders are used in order of which they are received from the supplier. Empty cylinders are segregated from full cylinders. When facility employs cylinders with integral pressure gauge, a threshold pressure considered empty is established. Empty cylinders are marked to avoid confusion. Cylinders stored in the open are protected from weather. 11.3.1, 11.3.2, 11.3.3, 11.3.4, 11.6.5 (NFPA 99)</p> <p>This STANDARD is not met as evidenced by:                      . DEVIN Based on observation and interview, the building failed to ensure the proper separation of combustible material and stored oxygen tanks per the requirements of: 2012 NFPA 99, 11.3.2.3(2) and (11) Findings include: 1. On 10/02/2017, during a tour of the building from 10:30 am to 5:45 pm, combustible materials were observed being stored within 5 feet of filled oxygen storage tank racks located in the sprinkled</p>

4th floor Critical Care Clean Supply Room. 36148 2. On 10/03/2017, during a tour of the building from 8:00 am to 4:15 pm, an empty oxygen cylinder was observed unsecured in the Electrical HVAC Shop. A member of the maintenance staff was present when this deficiency was identified. .