Statement of Deficiencies	**(X1) Provider/Supplier/CLIA Identification Number**	**(X3) Date Survey Completed**
	883920	03/17/2026
Name of Provider or Supplier	**Street Address, City, State**	
Pediatric Place Of Union City, Llc	1345 Edwards Street, Union City, TN	

For information on the provider's plan to correct this deficiency, please contact the provider or the state survey agency.

(X4) ID Prefix Tag	**Summary Statement of Deficiencies** (Each deficiency should be preceded by full regulatory or LSC identifying information)
J0042	PHYSICAL PLANT AND ENVIRONMENT 491.6(b) Maintenance: The clinic . . . has a preventive maintenance program to ensure that: (1) All essential mechanical, electrical and patient-care equipment is maintained in safe operating condition; This STANDARD is not met as evidenced by: Based on the Rural Health Clinic's (RHC's) documentation review, the facility failed to develop and implement a system for preventive maintenance program to ensure all mechanical and electrical equipment were safe and functioning properly. The findings included: There was no documentation provided for surveyor review of preventative maintenance program to ensure all essential mechanical, electrical and patient-care equipment is maintained in safe operating condition.